600W,1000W,1500W Pure Sine Wave Inverter/Charger User's Manual



P/N: 614-00076-00

Updated on 2018 Oct 19

Manufacturer info:

Table of Contents

1 Important Safety Information
1.1 General Safety Precautions
1.2 Precautions When Working with Batteries
2 Introduction
2.1 General Information
2.2 Features
2.3 Mechanical Drawing
2.4 Electrical Performance
2.4.1 Invert
2.4.2 AC Charger
2.4.3 Transfer
2.4.4 Remote Operation
2.4.5 Protections
2.4.7 LED Indicator & LCD Remote
2.4.8 Audible Alarm
2.4.9 FAN Operation
2.4.10 DIP Switches
2.4.11 Auto Generator Start14
2.4.12 Battery Temperature Sensing14
2.4.13 Other Features
3 Installation16
3.1 Location
3.2 DC Wiring Recommendation16
3.3 AC Wiring Recommendations17
3.4 Grounding
3.5 Mounting Flange
4 Maintenance & Troubleshooting19
5 Warranty
Appendix 1 : SMART POWER Series Inverter/Charger Spec Sheet

1 Important Safety Information

Save This Manual! Read this manual before installation, it contains important safety, installation and operating instructions. Keep it in a safe place for future reference.

All wiring must follow the National Electric Code, Provincial or other codes in effect at the time of installation, regardless of suggestions in this manual. All wires should be copper conductors.

1.1 General Safety Precautions

1.1.1 Before installing and using the SMART POWER Series Pure Sine Wave Inverter/Charger, read the manual and cautionary markings on the Inverter/Charger enclosure. Be sure to read all instructions and cautionary markings for any equipment attached to this unit. Installers must be certified technicians or electricians.

1.1.2 This product is designed for indoor/compartment installation. Do not expose the inverter/charger to rain, snow, spray, bilge or dust. To reduce risk of hazard, do not cover or obstruct the ventilation openings. Do not install the inverter/charger in a zero-clearance compartment. Overheating may result. Allow at least one inch of clearance around the inverter for air flow. Make sure that the air can circulate freely around the unit. A minimum air flow of 145CFM is required.

1.1.3 To avoid a risk of fire and electronic shock. Make sure that existing wiring is in good electrical condition; and that wire size is not undersized. Do not operate the Inverter with damaged or substandard wiring.

1.1.4 This equipment contains components which can produce arcs or sparks. To prevent fire or explosion do not install in compartments containing batteries or flammable materials or in locations which require ignition protected equipment. This includes any space containing gasoline-powered machinery, fuel tanks, or joints, fittings, or other connection between components of the fuel system. See Warranty for instructions on obtaining service.

1.1.5 Do not dis-assemble the Inverter/Charger. It contains no user serviceable parts. Attempting to service the Inverter/Charger yourself may result in a risk of electrical shock or fire. Internal capacitors remain charged after all power is disconnected.

1.1.6 To reduce the risk of electrical shock, disconnect both AC and DC power from the Inverter/Charger before attempting any maintenance or cleaning. Turning off controls will not reduce this risk

CAUTION: Equipment damage

The output side of the inverter's AC wiring should at no time be connected to public power or a generator. This condition is far worse than a short circuit. If the unit survives this condition, it will shut down until corrections are made.

Installation should ensure that the inverter's AC output is, at no time, connected to its AC input.

WARNING: LIMITATIONS ON USE

SPECIFICALLY, PLEASE NOTE THAT THE INVERTER/CHARGER SHOULD NOT BE USED IN CONNECTION WITH LIFE SUPPORT SYSTEMS OR OTHER MEDICAL EQUIPMENT OR DEVICES. WE MAKE NO WARRANTY OR REPRESENTATION IN CONNECTION WITH THEIR PRODUCTS FOR SUCH USES. USING THE INVERTER/CHARGER WITH THESE PARTICULAR EQUIPMENTS IS AT YOUR OWN RISK.

1.2 Precautions When Working with Batteries

1.2.1 If battery acid contacts skin or clothing, wash immediately with soap and water. If acid enters eye, immediately flood eye with running cold water for at least 20 minutes and get medical attention immediately.

1.2.2 Never smoke or allow a spark or flame in vicinity of battery or engine.

1.2.3 Do not drop a metal tool on the battery. The resulting spark or short-circuit on the battery of other electrical part may cause an explosion.

1.2.4. Remove personal metal items such as rings, bracelets, necklaces, and watches when working with a lead-acid battery. A lead-acid battery produces a short-circuit current high enough to weld a ring or the like to metal, causing a severe burn.

1.2.5 To reduce the risk of injury, charge only rechargeable batteries such as deep-cycle lead acid, lead antimony, lead calcium gel cell, absorbed mat, and NiCad/NiFe or Lithium battery. Other types of batteries may burst, causing personal injury and damage.

1.2.6 Don't install the inverter near batteries, the inverter may heat battery electrolyte and cause corrosive fumes to vent and damage/corrode nearby electronics or metals.

2 Introduction

2.1 General Information

Thank you for purchasing the SMART POWER Series Pure Sine Wave Inverter/Charger.

The SMART POWER Series Pure Sine Wave Inverter/Charger is a transformer based inverter and battery charger with an unprecedented conversion efficiency of 90%.

This lines has two popular models: the 600 watt inverter, 1000 watt invertr.

It features power factor corrected, sophisticated multi-stage charging control and pure sine wave output with high surge capability to meet power needs of all sorts of demanding loads without putting the equipment at risk.

In response to the increasing demand of more advanced battery charging, our engineering team equipped the inverter with a Battery Temperature Sensing probe for increased charging precision.

The generous 300% surge capacity of 20 seconds makes it possible to support demanding inductive loads. The AC/Battery priority, auto generator start functionality and optional built-in charger make it ideally suitable to work in backup power or anti-idle applications.

When customized to Battery priority mode via a DIP switch, the SMART POWER inverter will extract maximum power from external power sources and a minimal cycle of battery will be required. With the availability of auto generator start, an electrical generator can be integrated into the system and started when the battery voltage goes low.

With audible buzzer and remote LCD panel, the inverter gives the users comprehensive information of the operation status, making it easier for maintenance and troubleshooting.

Thus the SMART POWER Series Pure Sine Wave Inverter/Charger is suitable for applications including renewable energy systems, utility, truck, RV and emergency vehicles etc.

To get the most out of the power inverter, it must be installed, used and maintained properly. Please read the instructions in this manual before installing and operating.


2.2 Features

- Smart remote LCD control
- Auto Generator Start
- Battery Temperature Sensing for increased charging precision

- Manual 50Hz/60Hz output frequency switch
- Maximum 90% conversion efficiency
- High surge output capability, 300% peak load for 20 seconds
- Low quiescent current
- Battery type selector for 8 types of batteries and de-sulphation for completely drained batteries
- 10ms transfer time from AC to battery for continuous load operation
- 15 sec DC to AC transfer delay, improved protection for generator driven loads
- Thermally controlled variable speed fan for more efficient cooling
- Extensive protections against various harsh situations

2.3 Mechanical Drawing





The actual configuration of AC may vary in different models.

2.4 Electrical Performance

2.4.1 Invert

Topology

The SMART POWER Series pure sine wave inverter/charger is built according to the following topology.

Invert: Full Bridge Topology.

Charge: Isolated Boost Topology

When operating in invert mode, the direct current (DC) that enters the inverter from the batteries is filtered by a large input capacitor and switched "On" and "Off" by the Metal Oxide Silicon Field Effect Transistors (MOSFET) at a rate of 50 Hz or 60Hz, and directed into the transformer which steps the voltage up to 230 or 120 volts. The unit has a 16bit, 4.9MHZ microprocessor to control the output

Battery type selector								
Switch	Description	Boost /	Float /					
setting	Description	Vdc	Vdc					
0	Charger Off							
1	Gel USA	14.0	13.7					
2	AGM 1	14.1	13.4					
3	Lithium Ion (LiFeP04)	14.6	13.7					
4	Sealed lead acid	14.4	13.6					
5	Gel EURO	14.4	13.8					
6	Open lead acid	14.8	13.3					
7	Calcium	15.1	13.6					
8	Do gulphotion	15.5 (4 Hours						
0	De sulphation	then Off)						
9	Not used							

voltage and frequency as the DC input voltage and/or output load varies.

Because of high efficiency MOSFETs and the heavy transformers, it outputs PURE SINE WAVE AC. The peak invert efficiency of SMART POWER Series is 90%.

Overload Capacity

The Power Star inverter charger has different overload capacities, making it ideal to handle demanding loads.

1 For 110% <Load<125% (±10%), no audible alarm in 14 minutes, beeps 0.5s every 1s in the 15th minute, and Fault (Turn off) after the 15th minute.

2 For 125% < Load <150% (±10%), beeps 0.5s every 1s and Fault (Turn off) after the 1 minute.

3 For $300\% \ge \text{Load} > 150\%$ (±10%), beeps 0.5s every 1s and Fault (Turn off) after 20s.

Caution:

After the inverter is switched on, it takes 3-5 seconds for it to self diagnose and get ready to deliver full power. Hence, always switch on the load(s) after a few seconds of switching on the inverter. Avoid switching on the inverter with the load already switched on. This may prematurely trigger the overload protection. When a load is switched on, it may require initial higher power surge to start. Hence, if multiple loads are being powered, they should be switched on one by one so that the inverter is not overloaded by the higher starting surge if all the loads are switched on at once.

2.4.2 AC Charger

The SMART POWER Series pure sine wave inverter/charger is equipped with an active PFC (Power Factor Corrected) multistage battery charger. The PFC feature is used to control the amount of power used to charge the batteries in order to obtain a power factor as close as possible to 1.

Unlike other inverters whose max charging current decreases according to the input AC voltage, SMART POWER Series pure sine wave inverter/charger is able to output max charge current as long as input AC voltage is in the range of 164-243VAC(95-127VAC for 120V model), and AC freq is in the range of 48-54Hz(58-64Hz for 60Hz model).

The SMART POWER Series pure sine wave inverter/charger has a very rapid charge current available, and the max charge current can be adjusted from 0%-100% via a liner switch on the DC side of the inverter. This will be helpful if this powerful charger apply charging on a small capacity battery bank.

Choosing "0" in the battery type selector will disable charging function.

There are three main charging stages:

Bulk Charging: This is the initial stage of charging. While Bulk Charging, the charger supplies the battery with controlled constant current. The charger will remain in Bulk charge until the Absorption charge voltage (determined by the Battery Type selection) is achieved.

Software timer will measure the time from charger start until the battery charger reaches 0.3V below the boost voltage, then take this time as T0 and $T0 \times 10 = T1$.


Absorb Charging: This is the second charging stage and begins after the absorb voltage has been reached. Absorb Charging provides the batteries with a constant voltage and reduces the DC charging current in order to maintain the absorb voltage setting.

In this period, the inverter will start a T1 timer; the charger will keep the boost voltage in Boost CV mode until the T1 timer has run out. Then drop the voltage down to the float voltage. The timer has a minimum time of 1 hour and a maximum time of 12 hours.

Float Charging: The third charging stage occurs at the end of the Absorb Charging time. While Float charging, the charge voltage is reduced to the float charge voltage (determined by the Battery Type selection*). In this stage, the batteries are kept fully charged and ready if needed by the inverter. If the A/C is reconnected or the battery voltage drops below $\frac{12Ndc}{24Ndc}$ the charger will reset

If the A/C is reconnected or the battery voltage drops below 12Vdc/24Vdc/48Vdc, the charger will reset the cycle above.

If the charge maintains the float state for 10 days, the charger will deliberately reset the cycle to protect the battery.



Battery Charging Processes

De-sulphation

The de-sulphation cycle on switch position 8 is marked in red because this is a very dangerous setting if you do not know what you are doing. Before ever attempting to use this cycle you must clearly understand what it does and when and how you would use it.

What causes sulphation? This occurs with infrequent use of the batteries, nor if the batteries have been left discharged so low that they will not accept a charge. This cycle is a very high voltage charge cycle especially designed to try to break down the sulphated crust that is preventing the plates from taking a charge and thus allow the plates to clean up and accept a charge once again.



The de-sulphation charging should not be carried out on batteries with good conditions.

Charging depleted batteries

The SMART POWER Series pure sine wave inverter/charger allows start up and through power with depleted batteries.

For 12VDC models, after the battery voltage goes below 10V, if the switch is still(and always) kept in "ON" position, the inverter is always connected with battery whose voltage doesn't drop below 2V, the inverter will be able to charge the battery once qualified AC inputs.

Before the battery voltage going below 9VDC, the charging can activated when the switch is turned to "Off", then to "ON".

When the voltage goes below 9VDC, and the power switch is turned to "OFF" or disconnect the inverter from battery, the inverter will not be able to charge the battery once again, because the CPU lose memory during this process.

Model Wattage	Battery Voltage	Charging Current
600W	12 Vdc	25 ± 5 Amps
1000W	12 Vdc	40 ± 5 Amps
1500W	12 Vdc	55±5 Amps
1000W	24 Vdc	20±5 Amps
1500W	24 Vdc	25 ± 5 Amps

Charging current for each model

The charging capacity will go to peak in around 3 seconds; this may probably cause a generator to drop frequency, making inverter transfer to battery mode.

It is suggested to gradually put charging load on the generator by switching the charging switch from min to max, together with the 15s switch delay, our inverter gives the generator enough time to spin up.

Changing max charging current

The battery type selector position of "0" will disable battery charger.

The "Charge Current Control" knob will enable the user to control the max charging current from 15% to maximum.

\land	Please use a small jeweler's style flat-head screwdriver to turn the charge current
	control switch gently to avoid breakage due to over-turning.
	To guarantee the best performance of AC charger when the AC input is from a
Cantiana	generator, the standby generator should be of at least 150% higher capacity than the
Caution:	inverter.
	Warning! Operation with an under-rated generator or generator with unqualified
	wave form may cause premature failure which is not under warranty.

2.4.3 Transfer

While in the Standby Mode, the AC input is continually monitored. Whenever AC power falls below the VAC Trip voltage (154 VAC, default setting), the inverter automatically transfers back to the Invert Mode

with minimum interruption to your appliances - as long as the inverter is turned on. The transfer from Standby mode to Inverter mode occurs in approximately 10 milliseconds. And it is the same time from Inverter mode to Standby mode.

Though it is not designed as a computer UPS system, this transfer time is usually fast enough to hold them up.

There is a 15-second delay from the time the inverter senses that continuously qualified AC is present at the input terminals to when the transfer is made. This delay is built in to provide time for a generator to spin-up to a stable voltage and avoid relay chattering. The inverter will not transfer to generator until it has locked onto the generator's output. This delay is also designed to avoid frequent switch when input utility is unstable.

2.4.4 Remote Operation

Apart from the switch panel on the front of the inverter, an extra LCD switch panel connected to the remote port at the DC side of the inverter through a RJ45 cable can also control the operation of the inverter. If an extra switch panel is connected to the inverter via "remote control port", together with the master switch panel on the inverter case, the two panels will be connected and operated in parallel, whichever first switches from "Unit Off" to "Power saver off" or "Power saver on", it will power the inverter on. If the commands from the two panels conflict, the inverter will accept command according to the following priority:

Power saver on> Power saver off> Power off

Only when both panels are turned to "Unit Off" position, will the inverter be powered off.

The whole SMART POWER Series inverter is designed with extraordinarily low idle power consumption which is approximately 1.5% of its rated power.

		0	L (/
Model	Power Saver Off	Power Save	r Auto
Widdei	Idle(Max)	3Secs(Max)	Unit Off Charging
600W	18W	7.5W	3W
1KW	22W	9W	3 VV
1.5KW	30W	12W	

SMART POWER Series Inverter/Charger Idle Power Consumption (in Watts)

For more detailed technical information, please contact us.

2.4.5 Protections

The SMART POWER Series inverter/charger is equipped with extensive protections against various harsh situations/faults.

These protections include:

- AC Input over voltage protection/AC Input low voltage protection
- Low battery alarm/High battery alarm
- Over temperature protection/Over load protection
- Short Circuit protection (1s after fault)
- Back feeding protection on the AC output

When Over temperature /Over load occur, after the fault is cleared, the master switch has to be reset to restart the inverter.

The Low battery voltage trip point can be customized from defaulted value of 10VDC to 10.5VDC through the SW1 on the DIP switch.

The inverter will go to Over-temp protection when the heat sink temps. $\geq 105 \ \mathbb{C} (221 \ \mathbb{F})$, and will go to Fault (shutdown Output) after 30 seconds. After temp drops to 90 $\ \mathbb{C} (194 \ \mathbb{F})$, the switch has to be reset to activate the inverter.

The SMART POWER Series Inverter has back feeding protection which avoids presenting an AC voltage on the AC input terminal in Invert mode.

After the reason for fault is cleared, the inverter has to be reset to start working.

Î **Battery Type Selector** Power Saver **Over Load** Over Temp Alarm nverter Mode ine Mode ast loat Charge AC MODE GREEN LED on "AC Input Mode" GREEN LED on "Invert Mode" INVERTER ON Yellow LED on "Fast CHG" FAST CHARGE FLOAT CHARGE GREEN LED on "Float CHG" OVER TEMP TRIP RED LED on "Over Temp" OVER LOAD TRIP RED LED on "Over Load" CHARGING GREEN LED on "Ready Position"

2.4.7 LED Indicator & LCD Remote

Please refer to 'Indicator and Buzzer' for the detailed information.

The inverter can be connected to a remote LCD control panel (sold separately).



The LCD displays inverter status including Battery Voltage AC input Voltage AC Output Voltage AC Input and Output Frequency Load Percentage Monitoring Inverter Alarms & Faults The LCD screen to automatically go dim in a few seconds after the switch is operated, saving about 0.1A current draw on the battery bank. The press bottom will allow the user to wake up the screen. This LCD panel is flush mountable, it support flush mount to surfaces like walls. One most sought-after feature of the LCD remote is the compatibility with SNMP card for remote monitoring of the inverter status on the internet.

2.4.8 Audible Alarm

The inverter also gives audible alarms when the following situations occur.

Battery Voltage Low	Inverter green LED Lighting, and the buzzer beep 0.5s every 5s.
Pottowy Voltogo High	Inverter green LED Lighting, and the buzzer beep 0.5s every 1s,
Battery Voltage High	and Fault after 60s.
	(1)110% <load<125%(±10%), 14="" alarm="" audible="" in="" minutes,<="" no="" th=""></load<125%(±10%),>
Invest Made Over Load	Beeps 0.5s every 1s in 15 th minute and Fault after 15 minutes;
Invert Mode Over-Load	(2)125% <load<150%(±10%), 0.5s="" 1s="" 60s;<="" after="" and="" beeps="" every="" fault="" td=""></load<150%(±10%),>
	(3)Load>150%(±10%), Beeps 0.5s every 1s and Fault after 20s;
Ower Termeneture	Heat sink temp. $\geq 105^{\circ}C(221^{\circ}F)$, Over temp red LED Lighting, beeps
Over Temperature	0.5s every 1s;

2.4.9 FAN Operation

For 600W-1.5KW models, there is one multiple controlled DC fan. The DC fans are designed to operate according to the following logic:

Condition	Enter Condition	Leave condition	Speed
HEAT SINK	$T \le 60^{\circ}C(140^{\circ}F)$	$T > 65^{\circ}C(149^{\circ}F)$	OFF
TEMPERATURE	65°C(149°F)≤T < 85 °C(185°F)	$T \le 60^{\circ}C(140^{\circ}F) \text{ or } T \ge 85^{\circ}C(185^{\circ}F)$	50%
	$T > 85 \degree C (185 \degree F)$	$T \leq 80^{\circ}C(176^{\circ}F)$	100%
CHARGER	$I \le 15\%$	$I \ge 20\%$	OFF
CURRENT	$20\% < I \le 50\%$ Max	$I \le 15\%$ or $I > 50\%$ Max	50%
	I > 50% Max	$I \leq 40\%$ Max	100%
LOAD Percentage	Load < 30%	$Load \ge 30\%$	OFF
(INV MODE)	$30\% \leq \text{Load} < 50\%$	$Load \le 20\%$ or $Load \ge 50\%$	50%
	Load $\geq 50\%$	$Load \le 40\%$	100%

Allow at least 1 inch of clearance around the inverter for air flow. Make sure that the air can circulate freely around the unit.

Fan noise level <60db at a distance of 1m

2.4.10 DIP Switches

Switch #	Switch Function	Position: 0	Position: 1
SW1(AC Priority)	Low Battery Trip Point	10.0VDC	10.5VDC
SW2(230Vac)	AC Input Range	176-242Vac ±4%	164-264Vac(40Hz+)±4%
SW2(120Vac)	AC Input Range	100-135Vac ±4%	90-135Vac(40Hz+)±4%
SW3	B Power Save Override ON/OFF		Power Saver On(3 sec)
		Charging	
SW4	Frequency Switch	50Hz	60Hz
SW5	Battery/AC Priority	AC Priority	Battery Priority

On the DC end of inverter, there are 5 DIP switches which enable users to customize the performance of the device to suit the specific configuration.

Low Battery Trip Volt:

Deep discharge of the lead acid battery and many others leads to high losses in capacity and early aging. Thus discharging a battery properly according to its characteristics is getting more and more important.

In different applications, different low voltage disconnection level is preferred. For example, for solar and renewable energy application, users many intend to have less DOD(depth of discharge) to prolong the battery cycle life. While for mobile or emergency power backup applications, users many intend to have more DOD to reduce battery capacity and on board weight.

Our inverter chargers are designed with circuit to shut off inverter at adjustable low battery cutoff voltage set points.

For 12VDC model in AC priority mode, the Low Battery Disconnect Volt is set at 10.0VDC at position 0 by default. It can be customized to 10.5VDC using SW1, this is to prevent batteries from over-discharging while there is only a small load applied on the inverter.

This low battery cutout voltages are bought up by 0.5 and 1.0 volt in Battery priority mode, giving the batteries more protection.

*2 for 24VDC, *4 for 48VDC

AC Input Range:

There are different acceptable AC input ranges for different kinds of loads.

For some relatively sensitive electronic devices, a narrow input range of 184-253VAC (100-135V for 120VAC models) is required to protect them.

While for some resistive loads which work in a wide voltage range, the input AC range can be customized to 154-253VAC (90-135V for 120VAC models), this helps to power loads with the most AC input power without frequent switches to the battery bank.

In order to make the inverter accept dirty power from a generator, when the SW2 is switched to position "1", the inverter will bypass an AC input with a higher voltage(164-264Vac for 230Vac models, 90-135Vac for 120Vac models) and wider frequency (40Hz plus for 50Hz/60Hz). Accordingly, the AC charger will also work in a higher voltage(174-254Vac for 230Vac models, 100-135Vac for 120Vac models) wider frequency range (43Hz plus for 50Hz/60Hz).

This will avoid frequent switches between battery and generator. But some sensitive loads will suffer from the low quality power.

The pros and cons should be clearly realized before you do the setting.

Power Saver & Unit Off Charging:

Under the Battery Priority Mode (SW5 in position "1"), the inverter can be switched between two modes: Power Saver Mode (SW3 in position "1") and Unit Off Charging Mode (SW3 in position "0"). The power Switch should be in "Power saver on" position all the time for using these functions.

In Power Saver Mode, the inverter is initially in standby mode and sends a pulse to detect the presence of a load every 3 seconds. Each pulse lasts for 250ms. The inverter will remain in standby mode until a load has been detected. Then it will wake up from standby mode and start to invert electricity from the battery bank to supply the load. As this function is under Battery Priority, the inverter will always prefer to invert electricity from battery first even there is a qualified AC input present. Only when the battery voltage is lower than the low voltage alarm point, will the inverter switch to AC input power to charge the battery and supply the load at the same time.

This Power Saver Mode can be changed to Unit Off Charging mode via SW3 by switching it to "0" position. (SW5 still in "1").

"Unit Off Charging" will enable the inverter charger to charge batteries as much as possible while without discharging them.

In "Unit Off Charging" mode, the inverter will stay in standby mode without sensing loads. It won't output any power even if a load is turned on, and only stay idle in this mode when there is no AC input.

When a qualified AC input is present, it will start charging the battery and transfer power to loads.

This feature is ideally suitable for applications where energy conservation for batteries is required.

Charging will be activated once qualified AC exists, while discharging is disabled.

The inverter only consumes as little as 3 watts in "Unit Off Charging" mode.

Output Frequency:

The output frequency of the inverter can be set at either 50Hz or 60Hz by SW4 which make the inverter charger an international models for most electricity systems.

AC/Battery Priority (SW5):

The Smart Power inverter chargers are designed with AC/Battery priority switch (DIP switch #5). Switch the battery priority selector to Position "0" for AC priority mode, Position"1" for battery priority mode. In AC priority mode, when AC input is present, the battery will be charged first, and the inverter will transfer the input AC to power the load. Only when the AC input is stable for a continuous period of 15 days will the inverter start a battery inverting cycle to protect the battery. After 1 normal charging cycle ac through put will be restored.

When you choose battery priority, the inverter will invert from battery despite the AC input. When the battery voltage reaches the low voltage alarm point which is (0.5Vdc for 12V, 1Vdc for 24V, 2V for 48Vdc) higher than "**Low Battery Trip Point**", the inverter will transfer to AC input, charge battery, and switch back to battery when the battery is fully charged. This function is mainly for wind/solar systems using utility power or generator as back up.

The AC/Battery Priority function can be activated by sliding the switch even when the inverter is in operation.

Note: In battery priority mode, when qualified AC inputs for the first time and the battery voltage is below 12.5Vdc (12.5Vdc for 12Vdc, 25Vdc for 24Vdc, 51Vdc for 48Vdc), the inverter will first carry out a cycle of bulk charging and absorb charging, the inverter will not go into float charging mode. Choosing the battery type selector to "0" will disable the built-in battery charger while still allow transfer through. When battery charger is disabled, if the battery is charged by external DC power to 13.5Vdc (13.5Vdc for 12Vdc, 27Vdc for 24Vdc, 54Vdc for 48Vdc), the inverter will go to battery priority mode again.

2.4.11 Auto Generator Start

The inverter can start up generator when battery voltage goes low.

When the inverter goes to low battery alarm, it can send a signal to start a generator and turn the generator off after battery charging is finished.


The auto gen start feature will only work with generators which have automatic starting capability. The generator must have start and stop controls [i.e., an electric starter and electric choke (for gasoline units)], and the safety sensors to be able to start and stop automatically.

There is an open/close relay (constant open) that will close and short circuit the positive and negative cables from a generator start control. The input DC voltage can vary, but the max current the relay can carry is 16Amp. The Auto Generator Start terminal pins are not polarized.

In addition, these two pins can also be used as dry contacts to send out "Low Battery Voltage" signal to an external alarm device.

This AGS relay can also carry AC voltage within its capacity.

This inverter will skip the float charging when it is set at battery priority mode, so that the generator will no longer be kept running to maintain a small charge on the batteries.



2.4.12 Battery Temperature Sensing

Applying the proper charge voltage is critical for achieving optimum battery performance and longevity. The ideal charge voltage required by batteries changes with battery temperature.

When the battery voltage is over 40° C (104°F), it will reduce the charging voltage by 0.1Vdc with every degree of temperature rise.

We recommend that you install Battery Temperature Sensors on all banks to protect your batteries and to provide optimal charging of each bank.

The battery temperature sensor mounts on the side of a battery or any other location where the precise temperature of battery can be detected such as battery mounting racks.

The following table describes approximately how much the voltage may vary depending on the temperature of the batteries.

Inverter Condition	Temperature on BTS	Charger Operation
Charger Mode	$BTS \ge 50^{\circ}C(122^{\circ}F)$	Automatically turns off charger
	BTS \leq 40 °C(104 °F)	Automatically turns on charger
Inverter Mode	$40^{\circ}\mathbb{C}(104^{\circ}\mathbb{F}) \le BTS \le 50^{\circ}\mathbb{C}(122^{\circ}\mathbb{F})$	Increases the low voltage shut down
	$40 C(104 \Gamma) \le B1S \le 50 C(122 \Gamma)$	point by 0.5Vdc
	$BTS \ge 50^{\circ}C(122^{\circ}F)$	Over Temp Fault

2.4.13 Other Features

Battery voltage recovery start

After low battery voltage shut off (10V for 12V model), the inverter is able to restore to work after the battery voltage recovers to 13V (with power switch still in "On" position). This function helps to save the users extra labor to reactivate the inverter when the low battery voltage returns to acceptable range in renewable energy systems.



Never leave the loads unattended, some loads (like a Heater) may cause accidents in such cases. It is better to shut everything off after low voltage trip than to leave your load in the risk of fire.

3 Installation

3.1 Location

Follow all the local regulations to install the inverter.

Please install the equipment in a location of Dry, Clean, Cool with good ventilation. Working temperature: -10° C to 50° C (-14° F to 122° F) Storage temperature: -40° C to 70° C (-40° F to 158° F) Relative Humidity: 0% to 95%, non-condensing Cooling: Forced air Warning! Operation in a condensing environment will void the warranty.

3.2 DC Wiring Recommendation

It is suggested the battery bank be kept as close as possible to the inverter. The following table is a suggested wiring option for DC cable with length from 1 meter to 5 meters.


Model	Battery	Minimum	Wire Gage	Model	Battery	Minimum Wire Gage		
Watt	Voltage	0~15ft	15~20ft	Watt	Voltage	0~15ft	15~20ft	
600 Watt				1000				
inverter	12 Vdc	8ga	бga	Watt	12 Vdc	4ga	2ga	
				inverter				
1000 Watt				1500				
inverter	24 Vdc	8ga	6ga	Watt	12 Vdc	2ga	3ga	
				inverter				
1500 Watt	24 Vdc	100	200					
inverter	24 v dC	4ga	2ga					

Please follow the above minimum wire size requirement.

One cable is always best, but if there is a problem obtaining for example 100mm & able, use 2*50mm & 3*35mm ²instead, as long as the square area adds up. Performance of any product can be improved by thicker cable and shorter runs (so if in doubt round up and keep the length as short as possible).

Battery cables must have crimped (or preferably, soldered and crimped) copper compression lugs unless aluminum mechanical lugs are used. Soldered connections alone are not acceptable.

Battery terminal must be clean to reduce the resistance between the DC terminal and cable connection. A buildup of dirt or oxidation may eventually lead to the cable terminal overheating during periods of high current draw. Use a stiff wire brush and remove all dirt and corrosion from the battery terminals and cables.



Reducing RF interference

To reduce the effect of radiated interference, twist the DC cables. To further reduce RF interference, shield the cables with sheathing /copper foil / braiding.

Taping battery cables together to reduce inductance

Do not keep the battery cables far apart. In case it is not convenient to twist the cables, keep them taped together to reduce their inductance. Reduced inductance of the battery cables helps to reduce induced voltages. This reduces ripple in the battery cables and improves performance and efficiency.

	The torque rating range for DC terminal is 12.5NM-20.5NM (9.25-15.19 ft. lbs.), and the suggested torque rating is 17NM (12.6 ft. lbs.). Over torquing may cause the bolt to break.
WARNING	Equipment Damage The inverter is not reverse polarity protected. Reversing the battery polarity on the DC input connections will cause permanent damage to the inverter which is not covered under warranty. Always check polarity before making connections to the inverter. The inverter contains capacitors that may produce a spark when first connected to battery. Do not mount in a confined a battery or gas compartment. Ensure the inverter is off before disconnecting the battery cables, and that AC power is disconnected from the inverter input.

3.3 AC Wiring Recommendations

We recommend using 12 to 14 AWG wire to connect to the ac terminal block.


When in AC mode the AC input power will supply both the loads and AC charger, a thicker wire gauge for AC Input is required. Please consult a qualified electrician about the specific wire gauge required in terms of wire material and inverter power.

Please do the wiring according to local regulations, call our tech support if you are not sure about how to wire any part of your inverter.

3.4 Grounding

Connect an AWG 8 gauge or greater copper wire between the grounding terminal on the inverter and the earth grounding system or the vehicle chassis.

3.5 Mounting Flange



4 Maintenance & Troubleshooting

This troubleshooting guide contains information about how to troubleshoot possible error conditions while using the SP Pure Sine Wave Inverter/Charger.

The following chart is designed to help you quickly pinpoint the most common inverter failures.

Indicator and Buzzer

					Indicator on top cover				LED on Remote Switch			
Status	Item	AC Line	INVERTER	FAST CHG	FLOAT CHG	OVER TEMP	OVER LOAD	READY	BATT	INVERTER	Alarm	Buzzer
Status	num	Mode ON	ON	TAST CHO	TEORI CIIG	TRIP	TRIP	ON	CHG	INVERTER	Alarm	Buzzer
	CC	\checkmark		\checkmark					\checkmark			
Line Mode	CV	\checkmark		√, blink					\checkmark			
Line Mode	Float	\checkmark			\checkmark				\checkmark			
	Standby	\checkmark										
Inverter	Inverter On		\checkmark							\checkmark		
Mode	Power Saver							\checkmark				
	Battery Low		\checkmark							\checkmark	\checkmark	Beep 0.5s every 5s
	Battery High		\checkmark							\checkmark	\checkmark	Beep 0.5s every 1s
												Refer to
	Overload On		\checkmark				\checkmark			\checkmark		"Audible
Inverter	Invert Mode		·				,				•	alarm"
Mode	Over-Temp On											Beep 0.5s every
	Invert Mode		\checkmark			\checkmark				\checkmark	\checkmark	1s
	Over-Temp On √ Line Mode											Beep 0.5s every
		\checkmark	\checkmark		\checkmark		\checkmark			\checkmark		\checkmark
	Over Charge	Over Charge √										Beep 0.5s every
			N	N	v	\checkmark					\checkmark	
	E L l-										Beep	
	Fan Lock											continuous
	Battery High		\checkmark							\checkmark		Beep
	Battery High		v							v		continuous
	Inverter Mode						\checkmark					Beep
	Overload											continuous
Fault Mode	Output Short						\checkmark					Beep
												continuous
	Over-Temp					\checkmark						Beep
												continuous
	Over Charge			\checkmark					\checkmark			Beep
												continuous
	Back Feed											Beep
	Short											continuous

Symptom	Possible Cause(s)	Recommended Solution(s)
Inverter will not turn on during initial power up.	Batteries are not connected, loose battery-side connections. Low battery voltage.	Check the batteries and cable connections. Check DC fuse and breaker.
	Low buildry voltage.	Charge the battery.
No AC output voltage and no	Inverter has been manually	Press the switch to Power saver
indicator lights ON.	transitioned to OFF mode.	on or Power saver off position.
Inverter overload indicator on	Excessive AC output load or AC output short Defective inverter	Check AC output loads and wiring
Inverter high temperature indicator on	Excessive ambient temperature or AC output load	Check AC output loads, increase ventilation, derate the inverter if ambient temperature is excessive.
AC output voltage is low and the inverter turns loads OFF in a short time.	Low battery.	Check the condition of the batteries and recharge if possible.
Charger is inoperative and unit	AC voltage has dropped	Check the AC voltage for proper
will not accept AC.	out-of-tolerance	voltage and frequency.
Charger is supplying a lower charge rate.	Charger controls are improperly set.	Refer to the section on adjusting the "Charger Rate".
	Low AC input voltage.	Source qualified AC power
	Loose battery or AC input connections.	Check all DC /AC connections.
Charger turns OFF while charging from a generator.	High AC input voltages from the generator.	Load the generator down with a heavy load. Turn the generator output voltage
Constraints locale (There where the There are the set of the the	down.
Sensitive loads turn off	Inverter's Low voltage trip voltage	Choose narrow AC voltage in the
temporarily when transferring between grid and inverting.	may be too low to sustain certain loads.	DIP switch, or Install a UPS if possible.
Noise from Transformer/case*	Applying specific loads such as hair drier	Remove the loads

*The reason for the noise from transformer and/or case

When in inverter mode and the transformer and/or case of the inverter sometimes may vibrate and make noise. The noise may come from transformer.

According to the characteristics of our inverter, there is one type of load which will most likely cause rattles of the transformer, that is a half-wave load, load that uses only a half cycle of the power(see figure 1). This tends to cause imbalance of magnetic field of transformer, reducing its rated working freq from 20 KHz to, say, maybe 15 KHz (it varies according to different loads). This way, the freq of noise falls exactly into the range (200Hz-20 KHz) that human ear can sense.

The most common load of such kind is hair drier.


If the noise is coming from the case;

Normally when loaded with inductive loads, the magnetic field generated by transformer keeps attracting or releasing the steel case at a specific freq, this may also cause noise.

This noise may also be generated the moment a load is detected in the power saver mode.

Reducing the load power or using an inverter with bigger capacity will normally solve this problem.

The noise won't do any harm to the inverter or the loads.



5 Warranty

We warrant this product against defects in materials and workmanship for a period of two years from the date of purchase and will repair or replace any defective SP Inverter when directly returned, postage prepaid, to manufacturer. This warranty will be considered void if the unit has suffered any obvious physical damage or alteration either internally or externally and does not cover damage arising from improper use such as plugging the unit into an unsuitable power sources, attempting to operate products with excessive power consumption requirements, reverse polarity, or use in unsuitable climates.

WARRANTY DOES NOT INCLUDE LABOR, TRAVEL CHARGES, OR ANY OTHER COSTS INCURRED FOR REPAIR, REMOVAL, INSTALLATION, SERVICING, DIAGNOSING OR HANDLING OF EITHER DEFECTIVE PARTS OR REPLACEMENT PARTS. THE WARRANTOR ASSUMES NO LIABILITY FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES OF ANY KIND. LOSS OR DAMAGE: Loss or damage in transit is the responsibility of the carrier. Any claim should be filed with the delivering transport company. Invoice, Bill of Lading and Delivery receipt with damage noted therein must accompany any claims for freight damage. Claims for shortage and lost shipments must be made in writing to the shipper within 3 days of the receipt of shipment. Claims not reported within this time frame will not be honored.

This warranty does not apply to and we will not be responsible for any defect in or damage to: a) the product if it has been misused, neglected, improperly installed, physically damaged or altered, either internally or externally, or damaged from improper use or use in an unsuitable environment; violations of the warnings in the manual will invalid the warranty.

b) the product if it has been subjected to fire, water, generalized corrosion, biological infestations, or input voltage that creates operating conditions beyond the maximum or minimum limits listed in the product specifications including high input voltage from generators and lightning strikes;

c) the product if repairs have been done to it other than by our company or its authorized service centers

Appendix 1 : SMART POWER Series Inverter/Charger Spec Sheet

Electrical Sp	ecifications			
1	Power Rating	600W inverter	1000W inverter	1500W inverter
Inverter Output	Continuous Output	<00 1 11	1000	1 500
	Power	600W	1000W	1500W
	Surge Rating(20s)	1800W	3000W	4500W
	Output Waveform	Pure Sine wave/Same as input(Bypass mode)		
	Nominal Efficiency	90%(Peak)		
	Line Mode Efficiency	>95%		
	Power Factor	0.9-1.0		
	Nominal Output Voltage RMS	120Vac		
	Output Voltage Regulation	±5% RMS		
	Output Frequency		50/60Hz ±0.3Hz	
	Short Circuit Protection	Yes, Current	Limit Function (Fau	lt after 1sec)
	Typical transfer Time		10ms(Max)	
	THD	Pure sine wave, less than 5% THD Typical		
	Nominal Input Voltage		12.0Vdc	
	Minimum Start Voltage	10.0Vdc		
	Low Battery Alarm	10.5Vdc / 11.0Vdc (Dependent on switch setting)		
	Low Battery Trip	10.0Vdc / 10.5Vdc (Dependent on switch setting)		
	High Voltage Alarm & Fault	16.0Vdc		
DC Input	High DC Input Recovery	15.5Vdc		
DC input	Low Battery Voltage Recover	13.0Vdc		
	Idle Consumption-Search Mode	< 25 W when Power Saver On		
		*2 for 24V model, *4 for 48V models		
	Input Voltage Range	Narrow: 100~135VAC/ 194-243Vac		
		Wide: 90~135VAC / 164V-263Vac		
AC Charge	Input Frequency Range	Narrow: 47-55±0.3Hz for 50Hz, 57-65±0.3Hz for 60Hz		
		Wide:43±0.3Hz plus for 50Hz/60Hz		
	Output Voltage	Depends on battery type		
	Charger Breaker Rating(120Vac)	7A	10A	10A

	Pure Sine Wav	e Inverter/Charger	User's Manual	•
	Charger Breaker Rating(230Vac)	7A	10A	10A
	Max Charge Rate	25A	45A	55A
	Over Charge Protection	15.7V for 12Vdc		
	Shutdown			
	Battery type	Fast Vdc		Float Vdc
	Gel U.S.A	14		13.7
	A.G.M 1	14.1		13.4
	Lithium Ion (LiFeP04)	14.6		13.7
	Sealed Lead Acid	14.4		13.6
	Gel Euro	14.4		13.8
	Open Lead Acid	14.8		13.3
	Calcium	15.1		13.6
	De-sulphation	15.5 for 4hrs		
	Remote Control	Yes. Optional		
	Input Voltage Waveform	Sine	wave (Grid or Gener	rator)
	Nominal Voltage		120Vac/230Vac	
	Low Voltage Trip		$80Vac/154Vac\pm4\%$	
	Low Voltage re engage		$90 Vac/164 Vac \pm 4\%$	
	High Voltage Trip		140Vac/253Vac ±4%	
	High Voltage re engage	135Vac/243Vac ±4%		1
	Max Input AC Voltage	150Vac/270VAC50Hz or 60Hz (Auto detect)Narrow: 47±0.3Hz for 50Hz, 57±0.3Hz for 60Hz		
	Nominal Input Frequency			
	Low Frequency Trip			
		Wide:40±0.3Hz for 50Hz/60Hz		
	Low Frequency	Narrow: 48±0.3Hz for 50Hz, 58±0.3Hz for 60Hz		
	re-engage	Wide:45±0.3Hz for 50Hz/60Hz		
	High Frequency Trip	Narrow: 55±0	.3Hz for 50Hz, 65±0	.3Hz for 60Hz
		Wide: No up limit for 50Hz/60Hz		
	High Frequency	Narrow: 54±0.3Hz for 50Hz, 64±0.3Hz for 60Hz		
	re-engage	Wide: No up limit for 50Hz/60Hz		
	Mounting	Wall mount		
Mechanical	Inverter	325x173x135mm/	362x173x135mm/	362x173x135mm/
Specification	Dimensions(L*W*H)	12.8x6.8x5.3"	14.3x6.8x5.3"	14.3x6.8x5.3"
	Inverter Weight	7.5KG/16.5lb	11KG/24.3lb	12.5KG/27.3lb

Shipping Dimensions(L*W*H)	435x230x205mm/	475x230x205mm/	475x230x205mm/
	17.1x9x8"	18.7x9x8"	18.7x9x8"
Shipping Weight	8.5KG/18.7lb	12KG/26.5lb	14KG/31lb
Display	Status LED		
Standard Warranty	1 Year		

*****Errors and omissions reserved.

Specifications in this manual are subject to change without prior notice.

P/N: 614-00076-00